

WHITE - DIVISION OF WATER RESOURCES
 CANARY - CLIENT'S COPY
 PINK - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 93677
 Permit No. _____
 Basin 105
 49182
 NOTICE OF INTENT NO. 49182
 8-9-04

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bramwell Homestead LLC.
 MAILING ADDRESS P.O. Box 28
Genoa, NV 89411

ADDRESS AT WELL LOCATION 2448 Centennial Drive
Genoa, Nevada 89411

2. LOCATION SW 1/4 SW 1/4 Sec. 4 T 13N
 PERMIT NO. 1319-04-001-002

N/S R 19E E Douglas County
 Subdivision Name _____

3. WORK PERFORMED
 New Well
 Deepen
 Replace
 Abandon
 Recondition
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Air
 Rotary
 RVC
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders & Clay Sand		0	174	174
Granite	x	174	238	64
T.D. 238		238		

8. WELL CONSTRUCTION
 Depth Drilled 238 Feet
 Depth Cased 238 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10-5/8 Inches To 50 Feet
 From 8-3/4 Inches To 238 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.9	.188	+2	238

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 178 feet to 198 feet
 From 218 feet to 238 feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 238 feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service Contractor
 Address P.O. Box 60130 Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387-B
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 07/15/2004

Date started 06/29/2004
 Date completed 07/02/2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	20	120	1 hour
	30	140	1 hour
	30+	200	1 hour
	30+	238	2 hour

RECEIVED
 04 JUL 19 PM 2:46
 STATE ENGINEERS OFFICE