WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93704
Permit No.
Basin 16

NOTICE OF INTENT NO. 52448

1. OWNER Kurt Stodtmeister
MAILING ADDRESS PO Box 383
Cedarville, NV 96104

ADDRESS AT WELL LOCATION 50 Miles North of Gerlach

2. LOCATION NE 1/4 NE 1/4 Sec. 15 T 36 N/S R 18 E Washoe County
PERMIT NO. 25930 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	
Clay		4	25	21
Sand and Gravel		25	45	20
Clay		45	55	10
Coarse sand w/pebbles		55	80	25
Sand and gravel w/clay		80	130	50
Sand and gravel		130	150	20
Clay		150	165	15
Gravel w/clay		165	185	20
Sand and clay		185	210	25
Tan Shale		210	225	15
Sandy clay		225	235	10
Whole clay w/pea gravel		235	260	25
Sand w/clay mix		260	300	40

RECEIVED
04 AUG 12 AM 11:55
STATE ENGINEER'S OFFICE

Date started 6/29/04, 19__
Date completed 7/8/04, 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
P/L 219	900	184	5 hrs

8. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
37	Inches	0 Feet	50 Feet
24	Inches	50 Feet	300 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30		.250	0	50
16		.250	+2	60

Perforations:
Type perforation Mill Slot
Size perforation .090
From 60 feet to 100 Double Row feet
From 100 feet to 180 Quad Row feet
From 180 feet to 300 Double Row feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 2 feet to 300 feet

9. WATER LEVEL

Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 56797

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 7/6/2004