WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93705
Permit No. 70103
Basin 97B

NOTICE OF INTENT NO. 52976

1. OWNER Gary & Sally Johnson
MAILING ADDRESS 1245 Argosy Rd
Reno NV 89506

ADDRESS AT WELL LOCATION 270 Doubleback Rd
Reno NV 89506

2. LOCATION SE ¼ NE ¼ Sec. 8 T. 20 N/S R. 19 E. Washoe County
PERMIT NO. 70103 (Issued by Water Resources) 082 10155 (Parcel No.) North Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock & Clay		0	100	100
Clay		100	185	85
Rock & Clay		185	272	87
Sand & Gravel		272	282	10
Clay		282	304	22
Sand & Gravel		304	310	6
Clay		310	330	20
Sand		330	333	3
Clay		333	343	10
Rock & Clay		343	349	6
Gravel		349	360	11
Global Position				
N: 39° 36' 54.2"				
W: 119° 52' 4.0"				

Date started 6/21, 2004
Date completed 6/28, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	240	4

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	360 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	3/16	2+	360

Perforations:
Type perforation Saw Slot
Size perforation 3/16
From 260 feet to 280 feet
From 300 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 93 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling & Pump Co. (Contractor)
Address 15045 Red Rock Rd (Contractor)
Reno NV. 89506
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed John F. Olenski (By driller performing actual drilling on site or contractor)
Date 7/1/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627