

OFFICE USE ONLY  
 Log No. 93707  
 Permit No. 27275  
 Basin 69

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44242

1. OWNER Fred Miller ADDRESS AT WELL LOCATION 162 Hwy 290  
 MAILING ADDRESS 162 Hwy 290 Winn. Nev 89445  
 2. LOCATION NW 1/4 SE 1/4 Sec 23 T 41 S R 39 E Humboldt County  
 PERMIT NO. 27275  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top soil</u>		<u>0</u>	<u>3'</u>	
<u>Layered sand &amp; gravel</u>		<u>3'</u>	<u>24'</u>	
<u>Ben clay</u>		<u>24'</u>	<u>42'</u>	
<u>Sand &amp; gravel</u>	<u>-</u>	<u>42'</u>	<u>172'</u>	
<u>Sand, gravels &amp; clays</u>	<u>-</u>	<u>172'</u>	<u>545'</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 545' Feet Depth Cased 545' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
28" Inches 0 Feet 545' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16"</u>		<u>.250</u>	<u>72</u>	<u>145'</u>
<u>16"</u>		<u>.250</u>	<u>205'</u>	<u>245'</u>
<u>16"</u>		<u>.250</u>	<u>305'</u>	<u>345'</u>
<u>16"</u>		<u>.250</u>	<u>365'</u>	<u>374'</u>
<u>16"</u>		<u>.250</u>	<u>484'</u>	<u>515'</u>

Perforations:  
 Type perforation Wing wrap  
 Size perforation .035 slot  
 From 145' feet to 205' feet  
 From 245' feet to 305' feet  
 From 345' feet to 365' feet  
 From 374' feet to 484' feet  
 From 515' feet to 545' feet

RECEIVED  
 04 JUL -9 AM 11:33  
 STATE ENGINEERS OFFICE

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 90'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 90' feet to 545' feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality good

Date started 5-25-04 2004  
 Date completed 6-30-04 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>1350</u>	<u>260'</u>	<u>24 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Riverside Inc Jeff Donly Contractor  
 Address P.O. Box 726 Parma Contractor  
Idaho  
 Nevada contractor's license number issued by the State Contractor's Board 0044881  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2110  
 Signed Jeff Donly  
 By driller performing actual drilling on site or contractor  
 Date 7-6-04