WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93713
Permit No.
Basin 108

NOTICE OF INTENT NO. 53044

1. OWNER PERI & SONS
MAILING ADDRESS 186 HWY 208
YERINGTON, NV 89447

ADDRESS AT WELL LOCATION 186 HWY 208

2. LOCATION SW 1/4 SW 1/4 Sec. 26 T 13 N/S R 25 E LYON County
PERMIT NO. _____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	
Medium sand		1	7	6
Sticky brown clay		7	32	25
Medium fine sand		32	50	18
Small gravel		50	82	32
Coarse sand		82	96	14
Sand gravel		96	160	64

RECEIVED 04 AUG 13 AM 10:46 STATE ENGINEER'S OFFICE

Date started 7/15/04, 19__
Date completed 7/24/04, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80		6 hrs

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 157 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
16 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+2	117

Perforations:
Type perforation Mill Slot
Size perforation .100
From 117 feet to 160 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 56797

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2158

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 8/10/200