WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93721
Permit No.
Basin 108
(51757)
NOTICE OF INTENT NO. 51757

1. OWNER Sue Freshman Frishman
MAILING ADDRESS SW SW RC 8-12-04
ADDRESS AT WELL LOCATION Hwy 208 N. 95A Yerington, Nv.

2. LOCATION W ¼ NW ¼ Sec. 3 T. 14 (14) N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 04-202-16 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 6 | |
| Gravel Sand | | 6 | 66 | |
| Gray Clay | | 66 | 120 | |
| Silt | | 120 | 141 | |
| Gravel Sand | ✓ | 141 | 240 | |

RECEIVED 04 JUN 30 AM 10:22 STATE ENGINEERS OFFICE

Date started 6-14, 2004
Date completed 6-15, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| Pro Ecad about | 60 | 6 hrs |

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 240 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 18.00 | 3/16 | +1 | 20 |
| 6 5/8 | 3.00 | SDR 21 | 20 | 240 |

Perforations:
Type perforation Scill Saw
Size perforation
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc Contractor
Address Po Box 544 Contractor
Silver Springs Nv. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1677
Signed By driller performing actual drilling on site or contractor
Date 6-14-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627