WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93707
Permit No.
Basin 105

NOTICE OF INTENT NO. 49124

1. OWNER Troy + Jenifer Wilken
MAILING ADDRESS 890 Vista Park Dr. Carson City Nv 89705
ADDRESS AT WELL LOCATION 2730 Kayne Ave. Minden NV

2. LOCATION NW ¼ NW ¼ Sec. 34 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. — Issued by Water Resources | Parcel No. 142034201056 | Subdivision Name —

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-
SAND, SMALL gravels		0	40	40
CLAY		40	60	20
SAND, SMALL gravels	@ 80-90 ?	60	100	40
CLAY		100	120	20
SAND small gravels	x	120	160	40
CLAY		160	175	15
SAND small gravels	x	175	200	25

Date started 7.26 04
Date completed 7.28 04

RECEIVED 04 AUG -4 PM 1:45 STATE ENGINEERS OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80+		2 hours

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet
[redacted]
HOLE DIAMETER (SIZE)
10 5/8 Inches From 0 Feet To 200 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	140
			160	180

Perforations:
Type perforation factory slot
Size perforation 3/32 x 3"
From feet to feet
From 140 feet to 160 feet
From feet to feet
From 180 feet to 200 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 0001 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Nv Drilling + Pump LLC (Contractor)
Address 3540 Green Acres Dr (Contractor)
Carson City Nv 89705
Nevada contractor's license number issued by the State Contractor's Board 52078
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John E. Leisch
By driller performing actual drilling on site or contractor
Date 7-31-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627