

OFFICE USE ONLY  
 Log No. 93786  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53478

1. OWNER Jim Kozen ADDRESS AT WELL LOCATION 193 Taylor Creek Minden NV  
 MAILING ADDRESS 7343 Almaden Ln Gardsbad, CA 92009  
 2. LOCATION SE 1/4 NE 1/4 Sec. 4 T. 12 N/S R. 19 E Douglas County  
 PERMIT NO. 1219-04-001-034 Parcel No. Taylor Creek Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G - Large Rocks		0	56	56
D.G Red		56	68	12
D.G + Rocks		68	123	55
Granite		123	210	87

Abandoned - Twisted off drill bit @ 1401 could not fish out due to caving rocks on top of fish  
 Trimmed + pumped Neat Cement to 52ft  
 Approved by Ryan Clark 7-19-04

RECEIVED  
 04 AUG 11 AM 10:4  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 210 Feet Depth Cased plugged Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 10 Feet  
6 1/4 Inches 100 Feet 210 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-10, 2004  
 Date completed 7-13, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ground Pounders Well Drilling Contractor  
 Address 1374 HWY 395 Gardnerville NV 89410 Contractor  
PO BOX 7119 Gardnerville NV 89460  
 Nevada contractor's license number issued by the State Contractor's Board 0057531  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652  
 Signed George E. Steele  
 By driller performing actual drilling on site or contractor  
 Date 8/9/04