

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48325

1. OWNER Eric Taylor ADDRESS AT WELL LOCATION HC 61 Box 20
 MAILING ADDRESS 4061 Box 20 Battle Mountain NV 89820 Battle Mountain NV 89820

2. LOCATION SE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 20 T. 34 N/S R. 45 E. Lander County
 PERMIT NO. 010-106144 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>light sand</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u> </u>		<u>20</u>	<u>40</u>	<u>20</u>
<u> </u>		<u>40</u>	<u>100</u>	<u>60</u>
<u>Blue Clay</u>		<u>100</u>	<u>140</u>	<u>40</u>
<u>Brown Clay</u>		<u>140</u>	<u>160</u>	<u>20</u>
<u>Baldwin</u>		<u>160</u>	<u>240</u>	<u>80</u>
<u>Basalt</u>		<u>240</u>	<u>300</u>	<u>60</u>
<u>Rock n. Block</u>		<u>300</u>	<u>360</u>	<u>60</u>

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 360 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>.188</u>	<u>0</u>	<u>280</u>
<u>4.5</u>		<u>.188</u>	<u>280</u>	<u>360</u>

Perforations:
 Type perforation Factory
 Size perforation 3x18
 From 280 feet to 360 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 360 feet

9. WATER LEVEL
 Static water level 260 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 65 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name American Drilling & Pump Co. Contractor
 Address 3040 Calhoun St Waca NV 89445 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0020578
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1161
 Signed _____ by driller performing actual drilling on site or contractor
 Date 8-10-04

Date started 6-9 104
 Date completed 7-12 104

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60</u>	<u>—</u>	<u>2</u>

RECEIVED
 04 AUG 12 AM 11:31
 STATE ENGINEERS OFFICE