

USE ADDITIONAL SHEETS IF NECESSARY
 STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 93764
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **26940**

1. OWNER **BILL & PATTI TODD**
 MAILING ADDRESS **4350 W. JACOB ST. PAHRUMP, NV**

ADDRESS AT WELL LOCATION **4350 W. JACOB ST.**

2. LOCATION **NW 1/4 NE 1/4 Sec. 23 T 20**
 PERMIT NO. **41-431-21**
Issued by Water Resources Parcel No.

N/S R 52 E NYE County
GOLDEN SPRING RANCH UNIT 2
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	18	18
CALICHE		18	27	9
CLAY		27	48	21
CALICHE		48	52	4
CLAY		52	61	9
CALICHE	WB	61	75	14
CLAY		75	90	15
CALICHE	WB	90	114	24
CLAY		114	128	14
CALICHE	WB	128	140	12
CLAY		140	156	16
CALICHE	WB	156	175	19
CLAY		175	180	5

DWR
RECEIVED
AUG 04 2004
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled **180** Feet Depth Cased **180** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
10	0	180		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:
 Type perforation **SAWCUT**
 Size perforation **1/8 X 3**

From	To	Feet
80	100	feet
120	140	feet
160	180	feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **180** feet

9. WATER LEVEL
 Static water level **54** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
Contractor

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Address **P.O. BOX 4220** Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**
 Signed *[Signature]*
 By driller performing actual drilling on-site of contractor
 Date **8/2/2004**