WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

USE ADDITIONAL SHEETS IF NECESSARY
STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93776
Permit No.
Basin 162

NOTICE OF INTENT NO. 26932

1. OWNER CATHY COLGROVE
MAILING ADDRESS 1861 SANTOVITO
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1861 SANTOVITO

2. LOCATION NE 1/4 SE 1/4 Sec. 14 T 21 N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 44-752-13 (Parcel No.) MESA OESTE ESTATES UNIT2 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING		0	150	150
CLAY		150	160	10
CALICHE	WB	160	168	8
CLAY		168	180	12
CALICHE	WB	180	193	13
CLAY		193	220	27
CALICHE	WB	220	235	15
CLAY		235	250	15
CALICHE	WB	250	261	11
CLAY		261	275	14
CALICHE	WB	275	281	6
CLAY		281	300	19

DCNR/DWR
RECEIVED
AUG 17 2004
LAS VEGAS OFFICE

Date started 7/27/2004, 19__
Date completed 7/27/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.58	Inches	0	Feet	150	Feet
7.78	Inches	150	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.06	.236	0	300

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 180 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal EXISTING
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 300 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 8/11/2004