WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

USE ADDITIONAL SHEETS IF NECESSARY
STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93774
Permit No.
Basin 162

NOTICE OF INTENT NO. 26951

1. OWNER ALLEN & LINDA JACKSON
MAILING ADDRESS 5740 E. KELLOGG
PAHRUMP, NV

ADDRESS AT WELL LOCATION 5740 E. KELLOGG

2. LOCATION NE 1/4 SE 1/4 Sec. 16 T 21 N/S R 54 E NYE County
PERMIT NO. _____ Issued by Water Resources | 45-151-34 Parcel No. | KELLOGG HILLSIDE ESTATES Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DIRT & ROCK | | 0 | 12 | 12 |
| SAND & GRAVEL | | 12 | 60 | 48 |
| CEMENTED SAND & GRAVEL | | 60 | 87 | 27 |
| SAND & GRAVEL | WB | 87 | 200 | 113 |

DCNR/DWR
RECEIVED
AUG 17 2004
LAS VEGAS OFFICE

Date started 8/5/2004 , 19__
Date completed 8/7/2004 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 200 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 3.63 | .250 | 0 | 200 |
| | | | | |

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

| | | | | |
|---|---|---|---|---|
| From | 90 | feet to | 110 | feet |
| From | 130 | feet to | 150 | feet |
| From | 170 | feet to | 200 | feet |
| From | | feet to | | feet |
| From | | feet to | | feet |

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address P.O. BOX 4220 Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 8/10/04