WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93815
Permit No.
Basin 102

NOTICE OF INTENT NO. 26965

1. OWNER MARIO SERNA
MAILING ADDRESS 2851 W. PALM DR
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2851 W. PALM

2. LOCATION NW 1/4 SW 1/4 Sec. 19 T 19 N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) | Parcel No. 29-433-18 | Subdivision Name VALLEY VIEW ACRES

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT		0	3	3
CLAY		3	12	9
CALICHE		12	25	13
CLAY		25	45	20
CALICHE		45	58	13
CLAY		58	65	7
CALICHE	WB	65	78	13
CLAY		78	105	27
CALICHE	WB	105	120	15
CLAY		120	130	10
CALICHE	WB	130	141	11
CLAY		141	160	19
CALICHE	WB	160	180	20

DCNR/DWR
RECEIVED
SEP 07 2004
LAS VEGAS OFFICE

Date started 8/24/2004, 19__
Date completed 8/28/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.025	0	180

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 110 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 8/30/2004

USE ADDITIONAL SHEETS IF NECESSARY