WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93840
Permit No.
Basin 212

NOTICE OF INTENT NO. 26021

1. OWNER Fred & Irene Tenney
MAILING ADDRESS HCR 38 Box 182 LV, NV. 89166
ADDRESS AT WELL LOCATION Grand Teton & Scottie Rd, LV, NV,

2. LOCATION SE ¼ SW ¼ Sec. 7 T 19S N/S R 59 E Clark County
PERMIT NO. (Issued by Water Resources) 126-07-401-021 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	10	
Gravel		10	160	
Hard Limestone		160	165	
Bright Yellow Shale		165	185	
Hard Lime Stone		185	285	
Bright Yellow Shale		285	290	
Hard Limestone		290	380	
Yellow Shale		380	385	
Hard Limestone		385	410	
Limestone & Water	xx	410	420	
Yellow Shale		420	450	
Limestone & Water	xx	450	535	

DCNR/DWR
RECEIVED
AUG 0 2 2004
LAS VEGAS OFFICE

Date started 06/17/04, 20
Date complated 07/19/04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 535 Feet Depth Cased 535 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	450 Feet
8 3/4 Inches		450 Feet	535 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 6/8	16.94	.188	+2	50
6 1/2	SRD	PVC	+1	535

Perforations:
Type perforation Saw Cut
Size perforation 1/8 3 row
From 490 feet to 530 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 365 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 07-27-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627