WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93843
Permit No.
Basin 212

NOTICE OF INTENT NO. 26702

1. OWNER JV Properties LLC
MAILING ADDRESS 3455 Cliff Shadows
LV NV. 89129

ADDRESS AT WELL LOCATION 9825 Seeliger ST
Enterprise, Nev 89124

2. LOCATION NE ¼ NW ¼ Sec. 29 T. 22 S N/S R. 60 E. Clark County
PERMIT NO. Issued by Water Resources
176-29-101-031 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
NAC 534-420 - Section 8				
A. Depth of Well 624 ft.				
B. The depth to which the Materials used to plug the well were placed 624 ft.				
C. The size Type + Location of Perforations which were made in casing:				
Type - Knife (Rotary)				
Size - 1/4" x 1 1/2"				
Location: From Bottom up to 300 ft. 4 Times Around				
D. Debris Encountered: NONE				
E. Materials used to plug the well.				
24 Sack Cement Slurry				
+ 5 Sack Cement + Sand Slurry				
Section 9:				
Neat Cement Pumped in from Bottom up to 320 ft				
5 Sack Sand Slurry Poured in from 320 up to Surface				
State Log # 53708				

Date started 08-10-04, 20
Date completed 08-13-04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 380 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Contractor
Address 5360 N Bonita Vista St
Contractor
LV. NV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on site driller 552
Signed V. H. Dimick
By driller performing actual drilling on site or contractor
Date 08-16-04

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627