WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93844
Permit No.
Basin 216

NOTICE OF INTENT NO. 26727

1. OWNER Frehner Const.
MAILING ADDRESS

ADDRESS AT WELL LOCATION 29.8 Mile Marker North of Searchlight, Nev.

2. LOCATION NW ¼ NW ¼ Sec. 14 Dg To ~~17~~ 27S S N/S R 63 E Clark County
PERMIT NO. C-1024 (Issued by Water Resources) 233-00-001-017 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock
HYWAY USE

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
NAC 534-420 Section 8				
A. Depth of Well: 965 ft.				
B. Depth To Which The Materials used To Plug The well were placed: 965 ft				
C. The Type Size + Location of Perforations Which were made in The Casing: Type: Knife (Rotary) Size: 1/4" x 1 1/2" 4 Times Around Location: 965 ft up To 600 ft.				
D. Debris Encountered: None				
E. Materials used To Plug The Well: 24 Sack Slurry 965' to 565' 5 Sack Mix 25 ft To Surface Materials Slip Attached. Section 9: Neat Cement by Tremie Pipe 5 Sack Mix poured in.				

DON'T RECEIVE AUG 3 ... LAS VEGAS OFFICE

Date started 08-18-04, 20
Date complated 08-19-04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)
From To
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 660 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick
By driller performing actual drilling on site or contractor
Date 08-23-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627