WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93845
Permit No.
Basin 212

NOTICE OF INTENT NO. 26729

1. OWNER George Palmieri
MAILING ADDRESS 19651 Lanark St. Reseda, Calif. 91335
ADDRESS AT WELL LOCATION 4380 E Lake Mead Blvd. NLV. NV

2. LOCATION SW ¼ NW ¼ Sec. 20 T. T20 S N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) 140-20-201-016 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
NAC 534-420 Section 8				
A. Depth of Well: 150 ft				
B. The depth to which the materials used to plug the well were placed: 150 ft.				
C. The type, size + location of the perforations which were made in the casing:				
Type - Knife (Rotary)				
Size - 1/4" x 1 1/2"				
Location - 150 ft to 50 ft. 4 times around.				
D. The Depth Encountered: None				
E. Materials used to plug the well - Neat Cement				
Section 9				
Neat Cement by Tremie Pipe in upward direction				

DCNR/DWR RECEIVED AUG 30 2004 LAS VEGAS OFFICE

Date started 08-23-04, 20
Date complated 08-24-04, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL

Static water level 28 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista St (Contractor)
Las Vegas, Nev. 89149

Nevada contractor's license number issued by the State Contractor's Board 10062

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed V H Dimick
By driller performing actual drilling on site or contractor

Date 08-25-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627