WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93846
Permit No.
Basin 212

NOTICE OF INTENT NO. 26722

1. OWNER Sterling View LLC
MAILING ADDRESS 1700 W Horizon Ridge PW #203 Henderson, Nev 89012
ADDRESS AT WELL LOCATION 9225 W. Le Baron Ave Enterprise, Nev 89125

2. LOCATION SW ¼ NW ¼ Sec. 29 T 22 S N/S R 60 E Clark County
PERMIT NO. (Issued by Water Resources) 176-29-201-004 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
NAC-534-420 Section 8				
A. Depth of Well: 660 ft.				
B. The Depth To Which The Materials Used To Plug The Well Were Placed - 660 ft.				
C. The Type, Size, Location of Perforations Which were Made in The Casing: None - Waiver # R-1251				
D. Debris Encountered: None				
E. Materials Used To Plug The Well 24 Sack Slurry Materials Slips Attached				
Section 9: Neat Cement by Tremie Pipe Pumped				
State LOC # 81342				

Date started 08-09-04, 20
Date complated 08-13-04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 376 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H Dimick (Contractor)
Address 5360 N. Bonita Vista St (Contractor) LV, NV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 08-13-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627