COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93878
Permit No.
Basin 101
NOTICE OF INTENT NO. 52893

1. OWNER Jess Reid
MAILING ADDRESS 800 Lazy Heart
Fallon, NV 8406

ADDRESS AT WELL LOCATION Jess REid
835 Hunter Parkway
Fallon, NV 89406

2. LOCATION NE ¼ NW ¼ Sec 25 T 19 N R 28 E Churchill County

PERMIT NO. (Issued by Water Resources) | 008-314-56 (Parcel No) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Brown Clay		5	7	2
Brown Clay		7	10	3
Gray Clay		10	18	8
Brown Sand		18	24	6
Brown Clay		24	30	6
Brown/Gray Clay		30	45	15
Black Sand		45	54	9
Gray Black Clay		54	72	18
Black Gravel		72	85	13
Black Gray Clay		85	95	10
Brown Gravel	XX	95	104	9

RECEIVED 04 JUN 16 AM 10:28 STATE ENGINEERS OFFICE

Date started 04/15, 20 04
Date completed 04/15, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 104 Feet Depth Cased 104 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	104 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	104

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 100 feet to 104 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 104 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 06/11/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com