COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93883
Permit No.
Basin 101
NOTICE OF INTENT NO. 52902

1. OWNER Frank Woolsey
MAILING ADDRESS 2171 W Illiams Ave PMB280
Fallon, NV 8406

ADDRESS AT WELL LOCATION Frank Woolsey
4552 Hawk Drive
Fallon, NV 89406

2. LOCATION SW ¼ nw ¼ Sec 21 T 19 N R 28 E Churchill County
PERMIT NO. | Issued by Water Resources | 008-282-18 Parcel No | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	7	7
Brown Clay		7	18	11
Brown Gavel		18	32	14
Brown Clay		32	35	3
Gray Clay		35	45	10
lack Clay		45	48	3
Black/Gray Clay		48	51	3
Black Sand		51	55	4
Gray Clay		55	58	3
Brown Gravel		58	61	3
Gray Clay		61	70	9
Black/Brown Gravel		70	72	2
Brown Gravel	XX	72	75	3

RECEIVED 04 JUN 16 AM 10:28 STATE ENGINEERS OFFICE

Date started 06/04, 20 04
Date completed 06/04, 20 04

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	75 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	75

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 71 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 75 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Warren Parsons
By driller performing actual drilling on site or contractor
Date 06/11/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com