COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93884
Permit No.
Basin 101
NOTICE OF INTENT NO. 54558

1. OWNER Kent Whitaker
MAILING ADDRESS 2295 Sorensen Road
Fallon, NV 8406
ADDRESS AT WELL LOCATION Kent Whitaker
2295 Sorensen Road
Fallon, NV 89406

2. LOCATION SE ¼ NE ¼ Sec 23 T 18 N R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) 006-411-15 (Parcel No) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Brown Clay		6	11	5
Brown Gravel		11	25	14
Gray Clay		25	34	9
Black Sand		34	38	4
Black Clay		38	45	7
Black Sand		45	52	7
Brown Gravel		52	60	8
Clay		60	68	8
BLack Sand		68	75	3
Brown Gravel		75	80	5
Black Clay		80	86	6
Black Sand		86	92	4
Black Clay		92	98	6
Brown Gravel	XX	98	122	24

RECEIVED 04 JUN 16 AM 10:28 STATE ENGINEERS OFFICE

Date started 05/18, 20 04
Date completed 05/18, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 122 Feet Depth Cased 122 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	122 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	122

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 117 feet to 122 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 122 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 06/11/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com