COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93886
Permit No.
Basin 101
NOTICE OF INTENT NO. ~~54551~~ 54549

1. OWNER Randy Wildhaber
MAILING ADDRESS 2660 Highland Drive
Fallon, NV 8406

ADDRESS AT WELL LOCATION Randy Wildhaber
455 Corkill Lane
Fallon, NV 89406

2. LOCATION nw ¼ ne ¼ Sec 14 T 19 N R 27 E Churchill County
PERMIT NO. (Issued by Water Resources) 006-411-26 (Parcel No) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Brown Clay		5	10	5
Brown Gavel		10	14	4
Gray Clay		14	22	8
Brown Gravel		22	34	12
Gray Clay		34	36	2
Black Clay		36	42	6
Black/Gray Clay		42	44	2
Black Sand/Gravel		44	46	2
Black/Gray Clay		46	74	28
Black Sand		74	85	11
Black/Gray Clay		85	95	10
Black/White Gravel		95	112	17
Brown Gravel	XXX	112	118	6

RECEIVED
04 JUN -8 AM 10:51
STATE ENGINEERS OFFICE

Date started 05-17- , 20 04
Date completed 05/17 , 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 118 Feet Depth Cased 118 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	118 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	118

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 112 feet to 118 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 118 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 06/01/04

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com