WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93894
Permit No.
Basin 102

NOTICE OF INTENT NO. 53422

1. OWNER ~~Barnes Friesen~~
MAILING ADDRESS Rever Williams
1970 Banner
ADDRESS AT WELL LOCATION 1970 Banner ~~LEMON ST~~
SILVER SPRINGS, NV

2. LOCATION NE ¼ NE ¼ Sec. 31 T. ~~25~~ 18 N/S R. ~~18~~ 25 E. LYON County
PERMIT NO. Issued by Water Resources | Parcel No. 19-534-04 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	8	8
GRAY SANDY CLAY		8	18	10
GRAY STICKY CLAY		18	86	68
BLACK SANDY GRAVEL	X	86	126	40
BROWN STICKY CLAY		126	138	12
BROWN CLAY-GRAVEL	X	138	158	20
LARGE GRAVEL	X	158	190	32

RECEIVED
04 JUN 10 PM 3:39
STATE ENGINEERS OFFICE

Date started 20 MAY, 2004
Date complated 24 MAY, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		2.5

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	+1	10
6 5/8	4	SDR 21	10	190

Perforations:
Type perforation GRINDER CUT
Size perforation .040" X 3"
From feet to feet
From 180 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 56 ft
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 56 feet to 190 feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name
Contractor
Address BLAIN DRILLING & PUMP CO. INC.
P.O. Box 1255
Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board 46498

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167

Signed Jack Dotson
By driller performing actual drilling on site or contractor

Date

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627