WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93895
Permit No.
Basin 101

NOTICE OF INTENT NO. 52717

1. OWNER KAREN HULCHER
MAILING ADDRESS 5245 CODY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5850 HOOPER PLACE

2. LOCATION SW 1/4 NW 1/4 Sec. 29 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. (Issued by Water Resources) 008-572-23 Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	18	17
BROWN CLAY		18	20	2
BROWN SAND		20	75	55
GRAY CLAY		75	80	5
BROWN SAND		80	91	11
BROWN CLAY		91	96	5
GRAY SAND		96	120	24
GRAY CLAY		120	135	15
BROWN SAND	X	135	150	15

RECEIVED
04 JUN 10 AM 11:09
STATE ENGINEERS OFFICE

Date started 4/23/1904 , 19__
Date completed 5/9/1904 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
6 1/8	Inches	100	Feet	150	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	150

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 143 feet to 148 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 20'6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on-site or contractor)
Date 6/7/2004

USE ADDITIONAL SHEETS IF NECESSARY