

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 93902  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52885

1. OWNER Lee Hutchens  
 MAILING ADDRESS 2152 Reno Hwy  
Fallon, NV 89406  
 ADDRESS AT WELL LOCATION Lee Hutchens  
4387 Rancheria Drive  
Fallon, NV 89406

2. LOCATION 16 T 19 N R 28 E Churchill County  
 PERMIT NO. 55 008-122-31  
 Issued by Water Resources Parcel No Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Brown Clay		5	15	10
Gray Clay		15	32	18
Brown Gravel		32	45	13
Gray Blck Clay		45	48	3
Black Sand		48	56	8
Brown Gravel		56	60	4
Black Gravel/sand		60	64	4
Black Clay		64	70	6
Black Clay		70	72	2
Gray Clay		72	78	6
Black Sand		78	94	16
Brown Gravel		94	110	6
Black Brown Sand		110	118	8
Black Sand		118	130	12
Gray Clay		130	140	10
Black Sand/Gravel		140	150	10
Black Gravel		150	158	8
Black Clay		158	162	4
Black Sand		162	178	16
Gray Clay		178	183	5
Black Gray Clay		183	188	5
Brown Gravel	XX	188	193	5

8. WELL CONSTRUCTION  
 Depth Drilled 193 Feet Depth Cased 193 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 193 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 PVC	3.92	.258	20	193

Perforations:  
 Type perforation Saw Cut  
 Size perforation 1/8  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 196 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling Inc  
 (CONTRACTOR)

Address P.O. Box 1265  
 (CONTRACTOR)  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 06/01/2004

Date started 04/27, 20 04  
 Date completed 04/27, 20 04

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
<u>25</u>			
Draw Down (Feet Below Static)			
<u>1hr</u>			
Time (Hours)			

RECEIVED  
 ON JUN -8 AM 10:51  
 STATE ENGINEERS OFFICE