COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93903
Permit No.
Basin 101

NOTICE OF INTENT NO. 52897

1. OWNER Louis Turrietta
MAILING ADDRESS 870 Mark Avenue
Fallon,NV 89406

ADDRESS AT WELL LOCATION Louis Turrietta
2235 Smart Lane
Fallon, NV 89406

2. LOCATION nw ¼ ne ¼ Sec 35 T 19 N R 28 E Churchill County

PERMIT NO. | Issued by Water Resources | 008-812-07 Parcel No | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	4	4
Broan Gravel		4	17	13
Gray Clay		17	22	5
BrownGray Sand		22	35	13
Black Clay		35	37	2
Brown/Gray Sand		37	43	6
Black Clay		43	52	9
Gray Clay		52	64	12
Black Gravel w/sand		64	80	16
Clay		80	84	4
Brown Gravel	XX	84	98	14
Gray Clay		98	115	17

RECEIVED
04 JUN -8 AM 10:51
STATE ENGINEERS OFFICE

Date started 05/24, 20 04
Date completed 05/24, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	115 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6	3.92	.258	20	115

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 191 feet to 196 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to feet

9. WATER LEVEL
Static water level 12 30 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 06/01/2004

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com