COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93907
Permit No.
Basin 101

NOTICE OF INTENT NO. 52884

1. OWNER Lee Hutchens
MAILING ADDRESS 2152 Reno Hwy
Fallon,NV 89406

ADDRESS AT WELL LOCATION Lee Hutchens
4335 Rancheria Drive
Fallon, NV 89406

2. LOCATION sw ¼ nw ¼ Sec 16 T 19 N R 28 E Churchill County

PERMIT NO. | Issued by Water Resources | 008-122-26 Parcel No | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Brown Clay		8	11	3
Brown Gravel		11	15	4
Brown Clay		15	25	10
Gray Clay		25	32	6
Brown Sand/Gray		32	55	23
Blue Clay		55	66	11
Black Clay		66	70	4
Black Sand		70	85	15
Gray Clau		85	90	5
Black Sand		90	96	6
Brown Gravel		96	130	34
Gray Clay		130	145	15
Black Clay		145	156	11
Black Sand		156	165	9
Black Clay		165	170	5
Black Sand		170	178	8
Black Clay		178	188	10
Black Sand		188	195	7
Brown Gravel	XX	195	201	6

RECEIVED 04 JUN -8 AM10:51 STATE ENGINEERS OFFICE

Date started 04/30, 20 04
Date completed 04/30, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1hr

8. WELL CONSTRUCTION

Depth Drilled 201 Feet Depth Cased 201 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	201 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 PVC	3.92	.258	20	201

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 198 feet to 201 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 201 feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 06/01/2004

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com