

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 93908
 Permit No. _____
 Basin 101
 NOTICE OF INTENT NO. 52886

PRINT OR TYPE ONLY

1. OWNER Lee Hutchens
 MAILING ADDRESS 2152 Reno Hwy
Fallon, NV 89406
 ADDRESS AT WELL LOCATION 4413 Rancheria Dr
Fallon, NV 89406

2. LOCATION sw 1/4 nw 1/4 Sec 16 T 19 N R 28 E Churchill County
 PERMIT NO. 008-122-30
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	7	7
Brown Clay		7	14	7
Gray Clay		14	30	16
Brown Gravel		30	42	12
Brown Clay		42	44	2
Black Clay		44	46	2
Brown Gravel		46	58	12
Black Gravel/Sand		58	64	6
Black Clay		64	72	8
Black Sand		72	84	12
Black Gravel		84	90	6
Brown Gravel		90	130	40
Black Sand		130	136	6
Black Clay		136	145	9
Black Sand/Gravel		145	160	15
Gray Clay		160	165	5
Black Sand/Gravel		165	183	18
Gray Clay	XX	183	196	13

8. WELL CONSTRUCTION
 Depth Drilled 196 Feet Depth Cased 196 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches _____ Feet 196 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 PVC	3.92	.258	20	196

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 196 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc (CONTRACTOR)
 Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 06/01/2004

Date started 04/28, 20 04
 Date completed 04/28, 20 04

7. WELL TEST DATE

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	G.P.M. <u>25</u>	<u>1hr</u>

RECEIVED
 04 JUN - 8 AM 10:51
 STATE ENGINEERS OFFICE