WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

DW-17

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93911
Permit No.
Basin 137B

NOTICE OF INTENT NO. 52064

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain Nevada 89045
ADDRESS AT WELL LOCATION Round Mountain Gold Corp. Pit

2. LOCATION NW ¼ NE ¼ Sec. 30 T. 10 N R. 44 E. Nye County
PERMIT NO. 61791 T
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hole Plug		+1	150'	150'
Cemment		150'	270'	120'

Trip in Trimmie in
To 270' Pump
Cement in Hole up to
150' Let Cement
Set up for 12hr.
Trip Trimmie in to
150' Tag Cement
Trip out Trimmie
Pour Hole in Casing
up to Surface

RECEIVED
JUN - 1 PM 12:15
STATE ENGINEERS OFFICE

Date started 4-23, 2004
Date completed 4-23, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10¾	28.04	.250	+1	270

Perforations:
Type perforation Roscoe Moss Shadder Screen
Size perforation 3X3
From +1 feet to 270 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 150' to 270'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 183 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co. (Contractor)
Address P.O. Box 2748 (Contractor)
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1786
Signed Craig Diner (By driller performing actual drilling on site or contractor)
Date 4-23-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627