W[illegible]VISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93912
Permit No.
Basin 90

NOTICE OF INTENT NO. 51694

1. OWNER Lake Tahoe Nevada State Park
MAILING ADDRESS P.O. Box 8867
Incline Village, NV 89452

ADDRESS AT WELL LOCATION 2005 Hwy 28, Incline Village, Sand Harbor

2. LOCATION NW 1/4 NW 1/4 Sec. 2 T 15N N/S R 18E E Washoe County
PERMIT NO. 61743 Issued by Water Resources
130-350-01 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This well has been yielding gravel pack and sand into the pump intake for a couple of years. We believe that the Johnson Screen had seperated allowing gravels and sands to flow down to the pump intake. We installed 100' x 6 5/8" x .188 casing in the well as a liner pipe. 40' was double perforated pipe. We installed centralizers on the pipe and gravel packed from bottom to 20'. We developed the well and reinstalled the pump.				

RECEIVED
04 JUN -1 PM 12:31
STATE ENGINEERS OFFICE

Date started 5/21/2004 , 19__
Date completed 5/21/2004 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	75	39	1 1/2 hour

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	100	10

Perforations:
Type perforation Factory
Size perforation .060, double row.
From 90 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 5/21/04

USE ADDITIONAL SHEETS IF NECESSARY