WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93918
Permit No.
Basin 076

NOTICE OF INTENT NO. 52728

OWNER RAY LAVOIE
MAILING ADDRESS 1370 TRUCKEE LANE
FERNLEY, NV 89408

ADDRESS AT WELL LOCATION ~~1370~~ 1390 TRUCKEE LANE

2. LOCATION SW 1/4 SW 1/4 Sec. 10 T 20 N/S R 24 E LYON County
PERMIT NO. _____ Issued by Water Resources
021-051-45 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
COBBLES		1	18	17
BROEN CLAY		18	28	10
MC GRAVELS		28	40	12
BROWN CLAY		40	45	5
MC GRAVELS	X	45	90	45
BROWN CLAY		90	110	20
MC GRAVELS/CLAY	X	110	210	100
BLACK MEDIUM ROCK	X	210	245	35

Date started 5/20/1904 , 19__
Date completed 7/22/1904 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7		4 HRS

8. WELL CONSTRUCTION
Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
8 3/4	Inches	100	Feet	190	Feet
6 1/8	Inches	190	Feet	245	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	245

Perforations:
Type perforation MACHINE SLOT
Size perforation .080

From	183	feet to	188	feet
From	100	feet to	140	feet
From	50	feet to	80	feet
From		feet to		feet
From		feet to		feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed _____ By driller performing actual drilling on-site or contractor
Date 8/20/2004

USE ADDITIONAL SHEETS IF NECESSARY