WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93924
Permit No.
Basin 101

NOTICE OF INTENT NO. 53095

OWNER COUNTRY HOMES, INC
MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 7021 ANNETTE Ave. YF

2. LOCATION SE 1/4 SW 1/4 Sec. 1 T 19 N/S R 27 E CHURCHILL County
PERMIT NO. Issued by Water Resources
7-122-26 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	17	7
BROWN SAND		17	33	16
GRAY SAND		33	70	37
BLACK SILT/CLAY		70	90	20
GRAY SAND/CLAY		90	175	85
BROWN CLAY		175	180	5
BROWN SAND	X	180	191	11

Date started 7/29/~~1994~~ 2004, 19__
Date completed 7/30/~~1994~~ 2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION
Depth Drilled 191 Feet Depth Cased 191 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	191	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	191

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 185 feet to 189 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 23'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 8/26/2004

USE ADDITIONAL SHEETS IF NECESSARY