WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93931
Permit No.
Basin 093

NOTICE OF INTENT NO. 51701

1. OWNER Yomba Development Co.
MAILING ADDRESS 7507 Vista View Dr.
Reno, NV 89506

ADDRESS AT WELL LOCATION 3780 Antelope Valley Rd.

2. LOCATION NW 1/4 NE 1/4 Sec. 11 T 22N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources
79-500-43 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	1	1
Soft DG. sands		1	16	15
Brown sandy clay some DG. sands		16	48	32
Soft zone DG. sands		48	51	3
Brown sandy clay with DG. sands		51	91	40
Soft zone brown sands		91	93	2
Brown sandy clays		93	139	46
Soft zone		139	144	5
Brown sandy clays soft	x	144	160	16
Weatherd with clay streaks	x	160	180	20
Gray granite		180	234	54
Rusty weatherd granite		234	244	10
Fractured Granite	x	244	293	49
Gray Granite	x	293	302	9

Washoe County Permit #WL040113

Revised - gravel packed

Revised - log # 93931 and 93947 from section 12 to section 11

Date started 6/25/2004, 19__
Date completed 6/29/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	50+		3 HRS

8. WELL CONSTRUCTION
Depth Drilled 302 Feet Depth Cased 302 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	184	Feet
6 1/8	Inches	184	Feet	302	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	184
5"	10.79	.188	162	302

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 144 feet to 184 feet
From 262 feet to 302 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 153 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 7/1/2004

USE ADDITIONAL SHEETS IF NECESSARY