

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA

OFFICE USE ONLY

DIVISION OF WATER RESOURCES



Log No. 93934  
 Permit No. \_\_\_\_\_  
 Basin 103

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49771

INTENT OR TYPE ONLY

1. OWNER SCOTT SNELLING CONSTRUCTION  
 MAILING ADDRESS 318 SYDNEY LN  
DAYTON, NV 89403

ADDRESS AT WELL LOCATION 150 BRANTINGHAM CT  
DAYTON, NV 89403

2. LOCATION SE 1/4 NW 1/4 Sec 9 T 16 N R 22 E LYON County

PERMIT NO. SW 16-371-32

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

8. WELL CONSTRUCTION

| Material                            | Water Strata | From | To  | Thick-ness |
|-------------------------------------|--------------|------|-----|------------|
| LARGE OBSIDIAN BOULDERS AND COBBLES |              | 0    | 21  | 21         |
| COBBLES AND GRAVELS                 |              | 21   | 110 | 89         |
| BROWN CLAY                          |              | 110  | 145 | 35         |
| SMALL SANDS AND CLAY                |              | 145  | 165 | 20         |
| BROWN CLAY                          |              | 165  | 193 | 28         |
| FACTURED GRAVELS                    | XXX          | 193  | 220 | 27         |

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              | 13.03               | .188                    | +2          | 20        |
| 6 5/8sdr21         | 4.06                | .216                    | 20          | 220       |

Perforations:  
 Type perforation \_\_\_\_\_ SAW CUT  
 Size perforation 3 X 3/32  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 220 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ 95 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 8/16, 20 04  
 Date completed 8/17, 20 04

Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)

7. WELL TEST DATE

Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706

| TEST METHOD:   | G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|--|------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>25+</u> | <u>35</u>                     | <u>3 HRS</u> |

Nevada contractor's license number issued by the State Contractor's Board 0055548

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed Rock Crane  
 By driller performing actual drilling on site or contractor

Date 8/25/04