

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 93942  
 Permit No. \_\_\_\_\_  
 Basin 105  
 NOTICE OF INTENT NO. 53518

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER KURT JOHNSON DEVELOPMENT ADDRESS AT WELL LOCATION 1139 LINDA ANNE CT  
 MAILING ADDRESS 248 MARK STREET GARDNERVILLE, NV 89410  
GARDNERVILLE, NV 89410

2. LOCATION SE 1/4 NESE 1/4 Sec 11-24 T 12 N R 20 E DOUGLAS County  
 PERMIT NO. 1220-11-001-016

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
HARD PAN CLAY		0	5	5
BROWN CLAY		5	15	10
COURSE GRAVELS		15	78	63
BROWN CLAY	(DRY)	78	134	56
BROWN GUMMY CLAY		134	162	28
FRACTURED GRAVELS	XX	162	200	38

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

From \_\_\_\_\_ To \_\_\_\_\_

10 5/8 Inches 0 Feet 200 Feet

\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>+2</u>	<u>20</u>
<u>6 5/8sdr21</u>	<u>4.06</u>	<u>.216</u>	<u>20</u>	<u>200</u>

Perforations:

Type perforation FACTORY MILL SLOT

Size perforation 3 X 3/32

From 160 feet to 200 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_

Depth of Seal 100  Neat Cement

Placement Method:  Pumped  Cement Grout

Poured  Concrete Grout

Gravel Packed:  Yes  No

From 100 feet to 200 feet

9. WATER LEVEL

Static water level \_\_\_\_\_ 100 feet below land surface

Artesian flow \_\_\_\_\_ G.P.M. 30 P.S.I.

Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)

Address 20 KIT KAY DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 0055548

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date 8/28/04

Date started 8/26, 20 04

Date completed 8/27, 20 04

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>40</u>	<u>3 HRS</u>