

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 93947
 Permit No. 1179
 Basin 1179



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **49068**

1. OWNER JON MULLER ADDRESS AT WELL LOCATION LOT 63 CORNOR
 MAILING ADDRESS 1020 MOUNTAIN VIEW DRIVE
ELY, NV 89301

2. LOCATION SW 1/4 NE 1/4 Sec. 12 T 15N N/S R 63E E WHITE PINE County
 PERMIT NO. 012-770-42 Parcel No. 012-770-42 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SUB SOIL		0	5	5
CLAY/GRAVEL		5	12	7
CEMENTED GRAVEL		12	15	3
CLAY & GRAVEL		15	51	36
GRAVEL		51	67	16
CLAY & GRAVEL		67	110	43
HARD CEMENTED GRAVEL		110	129	19
CALICHE CLAY		129	155	26
CEMENTED GRAVEL		155	209	54
CLAY/GRAVEL		209	218	9
VERY SOFT GRAVEL	X	218	235	17
HARD & SOFT CLAY/MIXED GRAVEL	X	235	326	91

RECEIVED
 04 AUG 20 4 10 56
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 326 Feet Depth Cased 326 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 326 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+0	25
6	SRD-17	PVC	26	326

Perforations:
 Type perforation MILL SLOT
 Size perforation 1/8X3
 From 286 feet to 326 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 54 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No 25'-54' Bentonite Grout
 From 54 feet to 326 feet

9. WATER LEVEL
 Static water level 210 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality _____

Date started 7/12/2004, 19
 Date completed 7/17/2004, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
APPROX	25		3

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. Contractor
 Address P.O. BOX 525 Contractor
ELKO, NEVADA 89803
 Nevada contractor's license number 1 HF
 issued by the State Contractor's Board 030904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Sharel Fertig
 By driller performing actual drilling on-site or contractor
 Date 8/17/2004