

OFFICE USE ONLY
 Log No. 93970
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51390

1. OWNER Cove Meadows Ranch ADDRESS AT WELL LOCATION Approximately 5 Miles SW of McGill, Nevada.
 MAILING ADDRESS P.O. Box 1023
McGill, Nevada 89318

2. LOCATION SE 1/4 SE 1/4 Sec 28 T 19 N R 63 E White Pine County
 PERMIT NO. APN 010-100-08 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------------------|--------------|------|-----|------------|
| Top Soil | | 0 | 3 | 3 |
| Clay | | 3 | 14 | 11 |
| Water Bearing Sand & Gravel | X | 14 | 43 | 29 |
| Sand & Gravel with Clay Stringers | | 43 | 53 | 10 |
| Clay | | 53 | 56 | 3 |
| Water Bearing Sand & Gravel | X | 56 | 67 | 11 |
| Clay | | 67 | 76 | 9 |
| Water Bearing Sand & Gravel | X | 76 | 90 | 14 |
| Sand & Gravel with Clay Stringers | | 90 | 111 | 21 |
| Clay | | 111 | 120 | 9 |
| Clay & Gravel | | 120 | 126 | 6 |

8. WELL CONSTRUCTION
 Depth Drilled 126 Feet Depth Cased 126 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 126 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6-5/8</u> | <u>12.92</u> | <u>.188</u> | <u>0</u> | <u>126</u> |

Perforations: Factory
 Type perforation _____
 Size perforation 1/8" X 2 1/2" 6 Rows
 From 63 feet to 126 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Feet Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 126 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301
 Nevada contractor's license number 14790
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Richard Lewis By Jurell D. Christiansen
 By driller performing actual drilling on site or contractor
 Date August 16, 2004

Date started July 22 2004
 Date completed July 25 2004

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>95</u> | <u>108</u> | <u>1</u> |

RECEIVED
 AUG 19 AM 10:46
 STATE ENGINEERS OFFICE