REPORT NO. A04.062

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 9397
PERMIT NO.
BASIN 100

NOTICE OF INTENT NO. 52138

1. OWNER Jeff Ledbetter
MAILING ADDRESS 3430 Canvas Back Reno, NV 89506
ADDRESS OF WELL 700 Little Valley
Cold Springs, NV 89506

2. WELL LOCATION SW 1/4 NW 1/4 SEC. 17 T 21 R 18 E Washoe COUNTY
PERMIT NO ____ PARCEL NO 087-400-08 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Gray, Yellow Rock		0		
Brown Yellow Clay		0	15	15
Mixed Rock & Reddish		15		
& Brown Sandy Clay		15	30	15
Clay Rock Mixed & Some Granite		30	125	95
Multi Color Rock Gravels & Sand		125	145	20
Hard Dark Blue Green Vol. Rock		145	160	15
Gravel & Dark Green Sands		160	240	80
Fractured Rock Gravels &		240		
Multi Color Sands	X	240	260	20
Dark Blue Fractured Rock		260	305	45
Fractured Dark Blue Rock		305		
& Greenish Silty Clay		305	351	46

RECEIVED AUG 26 AM 10:55 STATE ENGINEERS OFFICE

Notes: UTM:
0243293
4397372 Elevation: 5132'

Date Started 7/30/04 Date Completed 8/5/04

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		2HRS.

8. WELL CONSTRUCTION
Depth Drilled 351 Depth Cased 351

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 351 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	351

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 X 3
From 311 Feet to 351 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 351 Feet

9. WATER LEVEL
Static Water Level 109 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of n knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed [signature]
By driller performing actual drilling on site or contractor
Dated August 5, 2004