WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93977
Permit No.
Basin 105

NOTICE OF INTENT NO. 51695

1. OWNER Jeff & Kathy Walters
MAILING ADDRESS P.O. Box 55
Kirkwood, CA 95646

ADDRESS AT WELL LOCATION 858 Sheridan Lane,
Minden, NV 89423

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T 12N N/S R 19E E Douglas County
PERMIT NO. (Issued by Water Resources) 1219-14-001-015 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG		0	20	20
Brown DG w/mixed rock		20	40	20
Fracture	x	40	80	40
Hard Brown Granite		80	100	20
Fractured rock	x	100	140	40
Rock w/ small gravels	x	140	180	40
Brown Fractured rock	x	180	240	60

RECEIVED 04 AUG 26 AM 11:02 STATE ENGINEER'S OFFICE

Date started 7/15/2004, 19__
Date completed 7/17/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	150+		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	240

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 240 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 8/2/2004

USE ADDITIONAL SHEETS IF NECESSARY