WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93989
Permit No.
Basin 101

NOTICE OF INTENT NO. 52716

1. OWNER KOPAS KONSTRUCTION
MAILING ADDRESS P. O. BOX 5024
FALLON, NV 89406

ADDRESS AT WELL LOCATION 4190 RANCHERIA

2. LOCATION SW 1/4 NE 1/4 Sec. 16 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. (Issued by Water Resources) Parcel No. 008-122-16 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	18	17
BROWN CLAY		18	22	4
BROWN SAND		22	40	18
GRAY CLAY		40	41	1
GRAY SANDS		41	90	49
GRAY CLAY		90	93	3
BROWN SAND	X	93	113	20

RECEIVED
04 JUN -8 AM 10:54
STATE ENGINEERS OFFICE

Date started 3/17/1904 , 19__
Date completed 5/14/1904 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION
Depth Drilled 113 Feet Depth Cased 113 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6	Inches	50	Feet	113	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	113

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 106 feet to 111 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 26'1" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on-site or contractor)
Date 6/6/2004

USE ADDITIONAL SHEETS IF NECESSARY