1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93996
Permit No.
Basin 76

NOTICE OF INTENT NO. 57998

1. OWNER Joe Lewis
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3370 Richards Way Fernley NV

2. LOCATION SW ¼ NW ¼ Sec. 27 T. 20 N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources | 021-481-45 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel Boulder		0	53	
Tan Clay		53	58	
Gravel mix		58	89	
tan clay		89	105	
Gravel		105	153	
Gravel clay mix		153	230	
Gravel		230	255	
clay mix Gravel Cemented		255	265	
Gravel		265	255	
Tan Clay		255	320	
Gravel	✓	320	360	

RECEIVED 04 MAY 26 PM 1:08 STATE ENGINEERS OFFICE

Date started 4-13, 2004
Date complated 4-16, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Produced	about	15 GPM

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
8 3/4 Inches	60 Feet	360 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	71	20
6 5/8	13.00	SDR 71	20	360

Perforations:
Type perforation Scill Saw
Size perforation
From 280 feet to 300 feet
From 340 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 260' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Okar

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc Contractor
Address PO Box 599 Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 4-17-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627