WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94002
Permit No.
Basin 99

NOTICE OF INTENT NO. 34511

1. OWNER Pilkington / Sibbald
MAILING ADDRESS 7471 Findhorn Dr.
Reno, NV 89506 RC 6-16-04

ADDRESS AT WELL LOCATION
505 Clydesdale Dr.
Reno, NV 89506

2. LOCATION ~~NE~~ NW ¼ SE ¼ Sec. ~~34~~ 33 T. 24 X N/S R. 18 E. Washoe County
PERMIT NO. WL040060 (Issued by Water Resources) 078-311-04 (Parcel No.) Rancho Haven (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Hard Clay | | 0 | 8 | 8 |
| Sand | | 8 | 18 | 10 |
| Clay & Gravel | | 18 | 110 | 92 |
| Gravel | | 110 | 120 | 10 |
| Clay & Gravel | | 120 | 130 | 10 |

RECEIVED
04 MAY 28 AM 11:43
STATE ENGINEERS OFFICE

Date started 5-4-04, 19
Date completed 5-6-04, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | |

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 52 | Feet |
| 8 | Inches | 52 | Feet | 130 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | | .188 | 0 | 130 |
| | | | | |

Perforations:
Type perforation Factory
Size perforation 3/32
From 120 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 52'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Turner Drilling & Pump (Contractor)
Address 472-250 Johnstonville Rd. (Contractor)
Susanville, CA 96130

Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2261

Signed Brett Smith
By driller performing actual drilling on site or contractor
Date 5-6-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627