WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94003
Permit No.
Basin 99

NOTICE OF INTENT NO. 43730

1. OWNER Tom Deschryver
MAILING ADDRESS P.O.Box 1430
Truckee, CA 96130 rc 6-16-04
ADDRESS AT WELL LOCATION 16105 Red Rock Rd.
Reno, NV 89512

2. LOCATION ~~SW~~ NE ¼ SE ¼ Sec ~~10~~ 9 T 23 N X/S R 18 E Washoe County
PERMIT NO. WL030212 (Issued by Water Resources) 078-161-23 (Parcel No.) Rancho Haven (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	5	5
Brown DG Sand Clay		5	35	30
White Gravel 1"+		35	60	25
Blue Clay W/lg. Rocks		60	135	75
Sandy DG white w/some clay		135	320	185

RECEIVED 04 MAY 28 AM 11:43 STATE ENGINEERS OFFICE

**SANITARY SEAL INFO
Outside 10" 45' seal
Inside 10" 75' seal
Per Tom Gallagher on 4-26-04, drill two 6" holes on outside of 10" try to get 50'. Seal 10" in place. Then go with 6" and seal what we can there. 100' seal is secondary at this point.

Date started April 6, 2004, 19
Date completed April 30, 2004, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14	138 (78)	1

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	100 Feet
8 Inches		100 Feet	320 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		.188	0	115
6		.188	115	320

Perforations:
Type perforation Factory
Size perforation 3/32
From 130 feet to 135 feet
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No **
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Turner Drilling & Pump (Contractor)
Address 472-250 Johnstonville Rd. (Contractor)
Susanville, CA 96130
Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2261
Signed Brett Smith (By driller performing actual drilling on site or contractor)
Date 4/30/2004

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627