COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94041
Permit No.
Basin 212

NOTICE OF INTENT NO. 26625

1. OWNER CLARK COUNTY SANITATION
MAILING ADDRESS 5857 E FLAMINGO RD.
LAS VEGAS, NV 89122

ADDRESS AT WELL LOCATION 5857 E FLAMINGO RD.
LAS VEGAS, NV 89122 ( Primaries 11 & 12)

2. LOCATION E ¼ SW ¼ Sec 22 T 21 S R 62 E CLARK County

PERMIT NO. (Issued by Water Resources) Parcel No. CLARK (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 4-Pizometer (monitor) | | | | |
| Sandy Clay | | 0 | 8 | |
| Silt | | 8 | 12 | |
| Silt gray clay | | 12 | 40 | |

DCNR/DWR
RECEIVED
SEP 2004
LAS VEGAS OFFICE

Date started 9/3, 20 04
Date completed 9/14, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 40 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | 0250 | 0 | 40 |

Perforations:
Type perforation Machine
Size perforation 1/4"x2.5"x21 per ft.
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231
Signed
By driller performing actual drilling on site or contractor
Date 9/28/04


Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com