WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94081
Permit No.
Basin 162

NOTICE OF INTENT NO. 27085

1. OWNER SUSAN WRIGHT
MAILING ADDRESS 4731 W HARDY LN
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4731 W. HARDY LN

2. LOCATION SE 1/4 SW 1/4 Sec. 14 T 20 N/S R 52 E NYE County
PERMIT NO. (Issued by Water Resources) 41-493-08 (Parcel No.) GOLDEN SP. RANCH UNIT 3 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY | | 0 | 10 | 10 |
| CLAY & GRAVEL | | 10 | 70 | 60 |
| CALICHE | WB | 70 | 75 | 5 |
| CLAY | | 75 | 110 | 35 |
| CALICHE | WB | 110 | 121 | 11 |
| CLAY | | 121 | 140 | 19 |

DCNR/DWR
RECEIVED
OCT 20 2004
LAS VEGAS OFFICE

Date started 10/6/2004, 19__
Date completed 10/7/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10.75 | Inches | 0 | Feet | 140 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 3.63 | .25 | 0 | 140 |
| | | | | |

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on-site or contractor)
Date 10/8/04

USE ADDITIONAL SHEETS IF NECESSARY