

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 99094
 Permit No. _____
 Basin 162
 NOTICE OF INTENT NO. 26931

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SHANNON BRECIK
 MAILING ADDRESS 4701 W. HORN
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4701 W. HORN

2. LOCATION SE 1/4 NW 1/4 Sec. 14 T 20
 PERMIT NO. _____ Parcel No. 41-472-07

N/S R 52 E NYE County
GOLDEN SPRINGS RANCH UNIT 3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	10	10
CALICHE		10	35	25
CLAY		35	55	20
CALICHE	WB	55	67	12
CLAY		67	95	28
CALICHE	WB	95	108	13
CLAY		108	125	17
CALICHE	WB	125	136	11
CLAY		136	148	12
CALICHE	WB	148	156	8
CLAY		156	160	4

DCNR/DWR
RECEIVED
SEP 24 2004
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 0 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3
 From 90 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor

PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date 9/21/04

Date started 9/14/2004, 19
 Date completed 9/16/04, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			