

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26319

1. OWNER Manuel + Diana Hurtado ADDRESS AT WELL LOCATION 4995 Conquistador
MAILING ADDRESS 9870 Red Coach Con Quistador Las Vegas NV 89129 Clark County
2. LOCATION S.W. 1/4 S.W. 1/4 Sec. 31 T. 19 N/S R. 60 E.
PERMIT NO. 125-31-401-015 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay Gravel		0	30	30
Cemented Gravel		30	70	40
Clay Gravel		70	150	80
Clay Stone		150	200	50
Cemented Gravel		200	225	25
Clay Stone		225	250	25
Cemented Gravel/Clay		250	300	50
Clay Gravel Boulders		300	375	75
Limestone	✓	375	750	375

LICNR/DWR
RECEIVED
AUG 12 2004
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 750 Feet Depth Cased 745 Feet
HOLE DIAMETER (BIT SIZE)
From 10 Inches To 0 Feet 750 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 IN #440</u>			<u>+1</u>	<u>745</u>
<u>5 FT. 8 5/8 X 1 3/8</u>				

Perforations:
Type perforation Saw
Size perforation 1/4 X 12
From 685 feet to 745 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50+ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 545 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 8-4, 2004
Date completed 8-7, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>		<u>2 NRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling Contractor
Address 3955 Blue Diamond Rd. #4 Contractor
Las Vegas NV, 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
Signed Flord Mitchell
By driller performing actual drilling on site or contractor
Date 8-7-04