

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 94153
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 NOT WRITE ON BACK

NOTICE OF INTENT NO. 52775

1. OWNER West Ridge Homes ADDRESS AT WELL LOCATION #20 Desert Creek
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 NE 1/4 Sec 32 T 10 N/S R 24 E Lyon Co. County
 PERMIT NO. 10-761-07 Parcel No. Smith Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		1	3	
Cobbles		3	6	
Cobbles, Boulders		6	32	
Cobbles, Gravel		32	46	
Cobbles, Boulders		46	78	
Gravels		78	102	
Boulders, Cobbles		102	302	
Sand, Cobbles		302	384	
Cobbles, Boulders		384	408	
Sand, Gravel		408	418	
Boulders, Gravel		418	499	

8. WELL CONSTRUCTION
 Depth Drilled 499 Feet Depth Cased 499 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 1 Feet 100 Feet
8 3/4 Inches 100 Feet 499 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>499</u>

 Perforations:
 Type perforation 3/ Machine Pipe
 Size perforation 3/16 x 4 x 8 # news pipe
 From 440 feet to 460 feet
 From 480 feet to 498 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 500 (499) feet

9. WATER LEVEL
 Static water level 334 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jason Dullin Jr Contractor
 Address PO 599 Contractor
22. NV 89409
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 9/16/04

Date started 9/8/04, 20_____
 Date completed 9/15/04, 20_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>18-20</u>	<u>2</u>	<u>2 hrs</u>