WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94167
Permit No.
Basin 162

NOTICE OF INTENT NO. 26834

1. OWNER Rubin Aguilar
MAILING ADDRESS 5211 E. Old Spanish Trail CT.
Pahrump, NV 89061

ADDRESS AT WELL LOCATION
5211 E. Old Spanish Trail CT.

2. LOCATION N/W 1/4 N/W 1/4 Sec. 28 T 21S N/S R 54E E Nye County
PERMIT NO. _____ Issued by Water Resources | 45-371-38 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| See next line | x | 0 | 114 | 114 |
| brown loam with caleche strings | | | | |
| brown caleche | x | 114 | 123 | 9 |
| brown loam | x | 123 | 170 | 47 |

DCNR/DWR
RECEIVED
OCT 18 2004
LAS VEGAS OFFICE

Date started 8/31/04 , 19__
Date completed 8/31/04 , 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. **WELL CONSTRUCTION**
Depth Drilled 170 Feet Depth Cased 170+1 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 11 | Inches | 0 | Feet | 170 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Well Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 3.7 | .280 | 0 | 170 |
| | | | | |
| | | | | |

**Perforations:**
Type perforation sawcut
Size perforation .188
From 140 feet to 170 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 170 feet

9. **WATER LEVEL**
Static water level 50 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor
Address 5801 S. Homestead
Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [signature]
By driller performing actual drilling on-site or contractor
Date 10-12-04