

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 94173
 Permit No. _____
 Basin 162

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26843

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Nationwide ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2661 W. Retread 2661 W. Retread
Pahrump, NV 89060
 2. LOCATION N/W 1/4 S/W 1/4 Sec. 18 T 20S N/S R 53E E Nye County
 PERMIT NO. 36-202-34 Charlesten Park
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown loam</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>See next line</u>		<u>6</u>	<u>16</u>	<u>10</u>
<u>grey loam with caleche strings</u>				
<u>See next line</u>		<u>16</u>	<u>43</u>	<u>27</u>
<u>brown loam with caleche strings</u>				
<u>grey clay</u>		<u>43</u>	<u>49</u>	<u>6</u>
<u>brown loam</u>	<u>x</u>	<u>49</u>	<u>128</u>	<u>79</u>
<u>grey loam</u>	<u>x</u>	<u>128</u>	<u>160</u>	<u>32</u>

Date started 8/20/04 19____
 Date completed 8/20/04 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160+1 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 10-02-04

DCNR/DWR
 RECEIVED
 OCT 18 2004
 LAS VEGAS OFFICE